



CITY OF PERRIS

DEVELOPMENT SERVICES DEPARTMENT
BUILDING AND SAFETY DIVISION
135 N. "D" Street, Perris, CA 92570-2200
TEL: (951) 443-1029 FAX: (951) 943-3293

Listing of Exhaust Fans By Approved Agencies 2016 California Mechanical & Electrical Code

The entire fan system must be listed by an approved testing agency and properly labeled when the exhaust or make-up fan comes as a unit which consists of the following:

- Fan
- Motor connected to the fan by belt or direct drive
- Motor wired to junction box inside fan enclosure, or motor is pre-wired to outside the enclosure
- Motor and fan are in a factor enclosure.

The fan alone, may not be required to be listed and properly labeled. However, the motor and other electrical components are required to be listed and labeled by an approved testing agency under the following conditions.

- The fan is in its own enclosure
- The motor is mounted adjacent to the fan enclosure and a belt or direct drive connection is made to the fan
- The motor is not pre-wired. The electrician must wire from a disconnecting means to the inside of the motor.