

## **CITY OF PERRIS**

## DEVELOPMENT SERVICES DEPARTMENT BUILDING AND SAFETY DIVISION OFFICE OF THE FIRE MARSHAL

135 N. "D" Street, Perris, CA 92570-2200 TEL: (951) 443-1029 FAX: (951) 943-3293

## Required Fire-flow and Duration Worksheet

Project Address
Project Application Number
Dear Applicant, Your project has been reviewed based on the information provided within the submitted plans. The following are minimum requirements as determined by the 2013 California Fire Code, Appendix B (table B105.1) and Appendix C (table C105.1) for fire-flow and duration.
Project Information:
Construction Type:Sprinklers:YN
Square Footage:
Fire Requirements:
Fire-flow required (measured at 20 p.s.i.):G.P.M (flow may be reduced 50% when sprinklers provided)
Flow Duration:Hours
Minimum # of Hydrants:
Average Hydrant Spacing:Feet
Maximum Distance to Hydrant:Feet
For additional information see attached appendices. For questions please confreviewer at 951-443-1029.
Reviewer: Date: