S & PE B PE CO B	Development Services Depart Building & Safety Division 135 N. D Street Perris, CA. 92571 (951) 943-5003 www.cityofperris.org	ment	APPLICATION FOR BUILDING PERMIT			
WC. 191			Permit # PMT			
STREET ADDRESS:		Unit #:	APN #:			
DESCRIPTION OF WORK:						
			DCCUPANCY.			
SQUARE FEET:	VALUATION: <u>\$</u>		_ Түре:			
TYPE OF PERMIT:	mercial Industrial	□ Residential	□ Multi-Family	0		
Number of plans- Incomplet	e submittals will not be accepted:		□ Fire	□Mobile Home		
Plans: Title 24	Structural Calcs:	Truss Calcs: _	Other Please	e Specify:		
OWNER / TENANT						
Business Name:			Contact:			
Mailing Address:						
Office #:	Mobile #:	Email:				
APPLICANT	Same as: 🛛 Owner/Ten	ant * 🛛 Archit	ect * 🛛 Engineer	✤ □ Contractor		
Name:			Contact:			
Mailing Address:						
Office #:	Mobile #:	Email:				
CONTRACTOR	Owner-Builder: 🛛 Yes	□ No				
			Contact:			
Mailing Address:						
	Mobile #:					
State Contractor's License #:	Class:		City Business License	#:		
ARCHITECT						
			Contact:			
Mailing Address:						
	Mobile #:					
Signature:		Date:				

S PERE

Development Services Department 135 N. 'D' Street P) 951-943-5003 F) 951-943-6504 www.cityofperis.org

Non -Construction Certificate of Occupancy

PERMIT COST \$85.55 Non-Refundable

STEP 1: Prepare for your permit Non-Reft Before you can start this application/permit you will need the following:

□A completed Building Permit Application (last page)

Two copies of dimensioned floor plans (see attached sample)

**Eastern Municipal Water District (E.M.W.D.) or City of Perris Water Clearance is your responsibility to contact- fees may be applicable.

STEP 2: Come to City Hall for your permit

OFFICIAL USE ONLY Permit #:	Tenant/B	usiness Name:	
Site Address:			Bldg./Suite #:
Property Owner's Name:		APN #:	
Owner's Mailing Address:			Type of use:

STEP 3: Get the required inspections/signatures

Departments	Phone	Date	Approval Signature
A) Planning	951-943-4610		
 Building & Safety Inspection/ Fire Marshal 	951-949-5003		
C) Health Department Inspection	951-461-0284		
D) Development Services Department	951-943-5003		

New Business Change of Ownership Change of Change of Business Name
:

Detailed Instructions:

- **A.** □Business License verification for the new tenant is required. You can complete this task at the **<u>cashier's window within City Hall</u>**. Please provide a completed business license form to the cashier. **(951) 943-4610.**
- **B.** □Schedule an inspection with the **Building & Safety Dept. at (951) 956-2117.** The Building & Safety Inspector's signature is provided at the job site after the inspection is completed. All fixtures, office furniture, and equipment are to be in place for the inspection)
- **C.** \Box If you will be selling any food products, you will need to schedule an

inspection with the **County Health Dept. at (951) 461-0284.** The sign off is provided by the Health inspector/representative at the job site after the inspection is completed.

D. □Once all the above signatures have been obtained, the release form will be sent to the business license department.

A technician will verify that there are no outstanding fees due and will provide final sign off for the Certificate of Occupancy. The Certificate of Occupancy will be mailed to the Owner's mailing address in approximately 2-3 weeks.

Purpose of the Non-Construction Certificate of Occupancy:

Per Municipal Code 15.04.020, Section 111.1 Use and Occupancy states: "To ensure appropriate continued use of any occupied space, the building official will issue a new Certificate of Occupancy upon any change of tenant at the fee rates established by resolution of the City Council."



CITY OF PERRIS ++++ FIRE LIFE & SAFETY

135 N. 'D' Street + Perris + CA + 92571 + Telephone (951)943-5003 + fax (951)943-6504

Fire Safety Inspection Checklist

- 1. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. Commercial, multi-family residential and industrial buildings shall have a minimum of 12-inch numbers with suite numbers being a minimum of six inches in size. All suites shall have a minimum of 6-inch high letters and/or numbers on both the front and rear doors. Single family residences and multi-family residential units shall have 4-inch letters and/or numbers, as approved by the Fire Prevention Bureau.
- 2. Provide at least one 2A10BC fire extinguisher for every 3,000 square feet of space or 75 feet of travel distance. Extinguishers must have a tag verifying annual servicing and must be mounted 3-5 feet from the floor in plain view without obstructions (Restaurants and industrial businesses may require a specific size or type of fire extinguisher).
- 3. Lightweight, multi-plug extension cords and cube adapters are not allowed for use in businesses. Extension cords shall be of a commercial type and be in good working condition. Extension cords shall not be subjected to physical damage. Extension cords shall be maintained in good condition without splices, deterioration or damage. Extension cords must be a surge protector type cord.
- 4. Maintain 30 inches of clear access to circuit breaker panel(s). Provide proper labeling of breakers and provide blanks in any open space in panel.
- _____5. Extension cords and flex cords shall not be used in place of fixed wiring. Stapling or nailing of wiring is not permissible.
- _____6. All electrical and phone faceplates must be in place.
- _____7. All holes in walls and ceiling shall be properly sealed.
- _____8. Storage shall not be within 24 inches of ceiling or 18 inches from the bottom of sprinkler heads in sprinklered buildings.
- 9. Maintain 36 inches of clearance around water heater.
- 10. Storage under stairs is prohibited unless equipped with sprinklers and meets the clearance requirements of 18-inches from sprinkler head.
- ____11. Rubbish and trash build-up shall be maintained at a minimal level and removed daily.

- __12. Pressurized cylinders of any kind shall be properly secured at all times and have the necessary permits pulled from the fire prevention department.
- 13. Maintain 44 inches of clear access aisle width to exits.
- 14. Exit doors shall be operable without the use of a key or special knowledge or effort. All locking devices shall be of the approved type.

EXCEPTION: In group B, F, M, and S occupancies, key locking hardware may be used on the main exit when the main exit consist of a single door or pair of doors if there is a readily visible, durable sign on, or adjacent to the door stating, "THIS DOOR MUST REMAIN UNLOCKED DURING BUSINESS HOURS".

- _____15. For occupant load of 50 and greater, illuminated Exit signs are to be operable at all time with separate backup power source.
- 16. Emergency lighting must be operable at all times with separate backup power source. If there is no emergency lighting in the building then it will need to be installed.
- 17. Any hazardous materials that are to be used or stored shall have a hazardous materials permit. Application and package is available through the fire prevention office.
- 18. Maintain fire rated doors and self-closing hardware per the California Building Code.
- 19. Any modification to the Fire Sprinkler or Fire Alarm System shall be done by a licensed sprinkler or alarm contractor, with plans submitted to the Fire Department for approval.
- 20. New tenant spaces and new occupancy buildings shall require alarm notification devices. For multi tenant buildings an alarm notification device shall be placed in each suite. For existing buildings with new tenants an alarm notification device shall be required in each tenant space. For existing buildings that are not equipped with a fire alarm system or sprinkler monitoring system, new tenants or owners shall be required to install the appropriate type of alarm system.
 - _21. For any racking that is installed or is proposed to be installed please make sure the necessary racking permits are obtained from Building and Safety. For any racking that has storage 12-feet and greater, exceeds 500 square feet, then a separate high piled storage permit will be required by the fire department.
 - 22. Hood extinguishing systems shall be a UL300 type system. Proof of recent certification of system will be required. If the hood extinguishing system is not a current type system then the system will need to be upgraded and permits will need to be applied for and issued.
 - 23. All hood extinguishing systems must be tied in and monitored by the fire alarm system. If the hood extinguishing systems are not tied into the fire alarms system, they will be required to prior to obtaining certificate of occupancy.

- 24. A five year certificate for the fire sprinkler system will be required to be shown during certificate of occupancy inspection. This may be obtained from the landlord or building owner.
- _25. Current certificates for the fire alarm system shall be required during certificate of occupancy inspection.

