



CITY OF PERRIS
DEVELOPMENT SERVICES DEPARTMENT
BUILDING AND SAFETY DIVISION
135 N. "D" Street, Perris, CA 92570-2200
TEL: (951) 943-5003 FAX: (951) 943-3293

Smoke Alarms in New Single-Family Dwellings 2022 CALIFORNIA RESIDENTIAL CODE (CRC)

Location within dwelling units. **2022 CRC Section R314** In dwelling units, a smoke alarm shall be installed in each sleeping room and at a point centrally located in the corridor or area giving access to each separate sleeping area. When the dwelling unit has more than one story and in dwellings with basements, a smoke alarm shall be installed on each story and in the basement. In dwelling units where a story or basement is split into two or more levels, the smoke alarm shall be installed on the upper level, except that when the lower level contains a sleeping area, an alarm shall be installed on each level. When sleeping rooms are on an upper level, the alarm shall be placed at the ceiling of the upper level in close proximity to the stairway. In dwelling units where the ceiling height of a room open to the hallway serving the bedrooms exceeds that of the hallway by 24 inches or more, smoke alarms shall be installed in the hallway and in the adjacent room. Alarms shall sound an alarm audible in all sleeping areas of the dwelling unit in which they are located.

LOCATIONS: Refer to Section R314.3.3 of the 2022 CRC for more details

- A. Centrally located in the hallway (*if no hallway, the area adjacent to the bedroom door*) giving access to the bedrooms.
- B. In each bedroom
- C. Outside each separate sleeping area in the immediate vicinity of the bedrooms.
- D. On each additional story of the dwelling, including basements and habitable attics.
- E. In any room that opens into the hallway that has a ceiling level, at any location, 24 inches higher than the lowest ceiling level of the hallway.
- F. On the ceiling in close proximity to the stairway.
- G. On the lower level ceiling in close proximity to the stairway.
- H. In all the sleeping rooms.
- I. Smoke Alarms shall be installed not less than 3 feet (914 MM) horizontally from the door or opening of a bathroom that contains a bathtub or shower.

SMOKE ALARMS SHALL COMPLY WITH NFPA 72 AND SECTION R314

Refer to the 2022 CRC Section R314.4 for the Interconnection requirements.

For combination Alarms refer to the 2022 CRC Section R314.5 Combination Alarms

City Hall
Permit Center

Development Services Department
135 North 'D' Street
Perris, CA 92570

phone: (951) 943-5003
fax: (951) 943-3293

www.cityofperris.org

NOTE: Hallway (*corridor*) - A passageway giving access to rooms. Usually enclosed by walls between 3 feet and 5 feet in width.

AUDIBILITY: All detectors must be audible in the bedrooms. Connecting the detectors in series is not required.

NOTE: If any area of a bedroom is more than 30 feet from a detector, an additional detector shall be installed in the bedroom.

Section R314.6 - POWER SOURCE: Power is to come from the building wiring and shall be equipped with battery backup. It is not recommended to put the detectors on a dedicated circuit, they should be incorporated into one of the general lighting circuits. Since the detectors are connected in series, they shall be on only one general lighting branch circuit.

All smoke detectors are to be installed in accordance with the approved manufacturer's instructions. The above information is not intended to violate any manufacture's specifications or instructions but is to be used for interpretation of the Building Code.

NOTE: When additions are constructed, the existing house must comply with the City's handout for Smoke Detectors in Existing Single-Family Dwellings. **See also Section R314.8**