



# CITY OF PERRIS

DEVELOPMENT SERVICES DEPARTMENT  
BUILDING AND SAFETY DIVISION  
135 N. "D" Street, Perris, CA 92570-2200  
TEL: (951) 943-5003 FAX: (951) 943-3293

---

## ***Burial Depths for Underground Wireways***

*(Derived from Table 300.50, 2022 California Electrical Code (CEC) **changed from the 2019 codes**)*

This table defines the minimum burial depths for voltages from 0 to **1000 volts**. The burial depth is defined as the shortest distance measured from the surface (*finished grade, concrete or similar cover*) to the top of any buried conductor, cable or conduit. Lesser depths shall be permitted where SPECIFIED in the installation instructions of a listed low-voltage lighting system, and where cables and conductors rise for terminations or splices or where access is otherwise required. Where a conduit type listed in column 1,2, or 3 is combining with one of the circuit types in columns 4 and 5, the shallower depth of burial shall be permitted.

\* Unless you use approved direct burial cable, all wiring must be protected in conduit.

---

**Metric Conversion Formula**  
1-inch = 25.4 millimeters